

Amity School District

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008

Page 1 of 1

NOTE: The Lead Test Results are provided here in two (2) different units so you can choose which one you want to use on your information.

Source	Date Collected	Lab #	Lead, ug/liter or ppb	Lead, mg/liter or ppm
Room 103 faucet	7/25/2017	20170725-035	5.1	0.0051
Room 100 faucet	7/25/2017	20170725-036	25.3	0.0253
Room 106 fountain	7/25/2017	20170725-037	38.8	0.0388
Room 108 faucet	7/25/2017	20170725-038	8.3	0.0083
Room 108 fountain	7/25/2017	20170725-039	278.	0.278
Library Fountain	7/25/2017	20170725-040	18.6	0.0186
Kitchen (R) rinse sink	7/25/2017	20170725-041	48.2	0.0482