Water testing results

Amity School District Office

Location	Fixture ID Resluts	Action Taken Date Tested	
Kitchen Sink	22520000-001KF	0.391 None	5/14/2021
Bathroom Sink	22520000-002BF	0.735 None	5/14/2021
NW Outside Faucet	22520000-003OS	0.491 None	5/14/2021
N wall Faucet	22520000-004OS	3.25 None	5/14/2021

Amity Elementary School

Fixture location	Fixture ID	results	actions taken	Date Tested	Retest
Office staff Bathroom	22520100-001BF		5.1 none	4/30/2021	
Counsler RM drinking Fountian	22520100-002DW		16.4 Replace fixture	4/30/2021	0
Counsler RM faucet	22520100-003SF		22.3 Replace fixture	4/30/2021	6.29
Sick RM drinking fountian	22520100-004NF		45.5 Replace fixture	4/30/2021	7.49
Sick RM faucet	22520100-005DW		4.75 none	4/30/2021	
100 Drinking Fountian	22520100-006DW		2.5 none	4/30/2021	
100 Faucet	22520100-007CF		12.6 none	4/30/2021	
100 East Bathroom	22520100-008BF		1.33 none	4/30/2021	
100 West Bathroom	22520100-009BF		4.64 none	4/30/2021	
E Drinking fountian outside RM100	22520100-010DW		1.52 none	4/30/2021	
W Drinking fountian outside RM100	22520100-011DW		2.13 none	4/30/2021	
101 Drinking Fountian	22520100-012DW		8.61 none	4/30/2021	

101 faucet	22520100-013CF		4.24 none	4/30/2021	
Bathroom Faucet boys south Hall 1	22520100-014BF		3.94 none	4/30/2021	
Bathroom Faucet boys south Hall 2	22520100-015BF		1.35 none	4/30/2021	
Bathroom Faucet Girls South Hall 1	22520100-016BF		3.88 none	4/30/2021	
Bathroom Faucet Girls South Hall 2	22520100-017BF		2.5 none	4/30/2021	
102 Drinking Fountian	22520100-018DW		2.07 none	4/30/2021	
102 Faucet	22520100-019CF		0.947 none	4/30/2021	
103 Drinking Fountian	22520100-020DW		3.3 none	4/30/2021	
103 Faucet	22520100-021CF		10.5 none	4/30/2021	
104 Drinking Fountian	22520100-022DF		0.806 none	4/30/2021	
104 Faucet	22520100-023CF		0.726 none	4/30/2021	
Bathroom faucet boys west hall 1	22520100-024BF		0.747 none	4/30/2021	
bathroom faucet boys west hall 2	22520100-025BF		0.594 none	4/30/2021	
Drinking Fountian west hall 1	22520100-026DW		11.7 none	4/30/2021	
Drinking Fountian west hall 2	22520100-027DW		6.94 none	4/30/2021	
105 Drinking Fountian	22520100-028DW		2.27 none	4/30/2021	
105 Faucet	22520100-029CF		11.2 none	4/30/2021	
Bathroom faucet girls west hall 1	22520100-030BF		0.949 none	4/30/2021	

Bathroom Faucet girls west hall 2	22520100-031BF		0.696 none	4/30/2021	
Gym Drinking Fountian 1	22520100-032DW		3.25 none	4/30/2021	
106 Drinking fountian	22520100-033DW		1.72 none	4/30/2021	
106 Faucet	22520100-034CF		7.28 none	4/30/2021	
107 Drinking Fountian	22520100-035DW		15.9 Replace fixture	4/30/2021	0
107 Faucet	22520100-036CF		4.94 none	4/30/2021	
108 Faucet	22520100-037CF		2.96 none	4/30/2021	
108 Drinking Fountian	22520100-038DW		0.935 none	4/30/2021	
109 Faucet	22520100-039CF		7.68 none	4/30/2021	
109 Drinking Fountian	22520100-040DW		2.41 none	4/30/2021	
110 Faucet	22520100-041CF		10.4 none	4/30/2021	
110 Drinkgin Fountian	22520100-042DW		2.41 none	4/30/2021	
Library Work Room Faucet	22520100-043SF		2.33 none	4/30/2021	
Library Work Room Drinking Fountian	22520100-044DW		27.8 Replace fixture	4/30/2021	0
Gym bathroom Faucet Boys 1	22520100-045BF		16.3 Replace fixture	4/30/2021	9.57

Gym bathroom Faucet Boys 2	22520100-046BF	5.47 none	4/30/2021	
Gym bathroom Faucet Boys 3	22520100-047BF	2.33 none	4/30/2021	
Gym Bathroom Faucet Girls 1	22520100-048BF	9.65 none	4/30/2021	
Gym Bathroom Faucet Girls 2	22520100-049BF	5.82 none	4/30/2021	
Gym Bathroom Faucet Girls 3	22520100-050BF	4.83 none	4/30/2021	

111 Drinking Fountian	22520100-051DW	1.29 none	4/30/2021	
111 Faucet	22520100-052CF	5.7 none	4/30/2021	
112 Drinking Fountain	22520100-053DW	1.78 none	4/30/2021	
112 Faucet	22520100-054CF	15.6 Replace fixture	4/30/2021	1.28
Addition Bathroom faucet Girls 1	22520100-055BF	0.466 none	4/30/2021	
Addition Bathroom Faucet Girls 2	22520100-056BF	0.577 none	4/30/2021	
Addition Bathroom Faucet Boys 1	22520100-057BF	0.747 none	4/30/2021	
Addition Bathroom Faucet Boys2	22520100-058BF	1.06 none	4/30/2021	
116 Faucet	22520100-059CF	0.7266 none	4/30/2021	
116 Drinking Fountian	22520100-060DW	0.678 none	4/30/2021	
Addition Drinking Fountian	22520100-061DW	0.225 none	4/30/2021	
113 Faucet	22520100-062CF	0.696 none	4/30/2021	
113 Drinking Fountian	22520100-063DW	1.27 none	4/30/2021	
114 Faucet	22520100-064CF	1.14 none	4/30/2021	
114 Drinking Fountian	22520100-065DW	0.67 none	4/30/2021	
115 Drinking Fountian	22520100-066DW	0.8 none	4/30/2021	
115 Faucet	22520100-067CF	0.836 none	4/30/2021	
Staff Room Womens Faucet	22520100-068BF	1.29 none	4/30/2021	
Staff Room Mens Faucet	22520100-069BF	2.29 none	4/30/2021	
Staff Room Faucet	22520100-070SF	2.64 none	4/30/2021	
Staff Room side Faucet	22520100-071SF	0.629 none	4/30/2021	
Kitchen Faucet Rinse sink back 1	22520100-072KF	4.26 none	4/30/2021	
Kithcen Faucet Rinse Sink back 2	22520100-073KF	1.44 none	4/30/2021	
Ice machine	22520100-074IM	1.08 none	4/30/2021	
Kithcen Bathroom faucet	22520100-075BF	6.37 none	4/30/2021	
Kitchen Hand washing sink	22520100-076SF	3.56 none	4/30/2021	

Gym Drinking Fountian 2	22520100-077DW	2.02 none	4/30/2021	
Kitchen faucet Rinse sink east wall 1	22520100-078KF	165 Replace fixture	4/30/2021	0
kitchen Rinse Sink East wall 2	22520100-079KF	20.4 Replace fixture	4/30/2021	2.68
Kitchen Faucet Rinse Sink South Wall 1	22520100-080KF	12.8 none	4/30/2021	
Kitchen Faucet Rinse sink South Wall 2	22520100-081KF	0.834 none	4/30/2021	
Mod Bathroom Faucet	22520101-082BF	0.67 none	4/30/2021	
Preschool Bathroom Faucet	22520101-083BF	0.435 none	4/30/2021	
Outside Faucet 100	22520100-084OS	4.72 none	4/30/2021	
Outside Faucet Office	22520100-085OS	0.315 none	4/30/2021	
Outside Faucet 115	22520100-086OS	23.9 Replace fixture	4/30/2021	0
Outside Faucet 108	22520100-087OS	4.97 none	4/30/2021	
117 faucet	22520100-088CF	27.4 Replace fixture	4/30/2021	0
117 drinking fountian	22520100-89DW	4.07 none	4/30/2021	

Amity Middle School

Fixture Location	Fixture ID	Results Action Taken	Date Tested	Retest
Sick Room	22520200-001NS	3.64 None	5/14/2021	
Drinking Fountian west hall	22520200-002DW	0 None	5/14/2021	
Bottle fill west hall	22520200-003DW	0 None	5/14/2021	
Rm 1 West Island Sink	22520200-004CF	27.5 Replaced Fixture	5/14/2021	0
Rm 1 wall Sink West	22520200-005CF	7.72 None	5/14/2021	
Rm 1 Wall Sink East	22520200-006CF	57.4 Replaced Fixture	5/14/2021	0
Work Rm Faucet	22520200-007SF	1.31 None	5/14/2021	
Girls Bathroom east	22520200-008BF	0.389 None	5/14/2021	
Girls Bathroom Middle	22520200-009BF	0.682 None	5/14/2021	
Girls Bathroom West	22520200-010BF	0.641 None	5/14/2021	
Office Drinking Fountian	22520200-011DW	0.284 None	5/14/2021	
Boys Bathroom East	22520200-012BF	0.209 None	5/14/2021	

Boys Bathroom West	22520200-013BF	0.297 None	5/14/2021	
Rm 4 Faucet	22520200-014CF	3.73 None	5/14/2021	
Rm 5 Faucet	22520200-015CF	2.86 None	5/14/2021	
Rm 9 Faucet	22520200-016CF	20.5 Replaced Fixture	5/14/2021	0
Rm 10 Faucet	22520200-017CF	8.64 None	5/14/2021	
South Hall Drinking Fountian	22520200-018DW	0.229 None	5/14/2021	
Rm 11 Faucet	22520200-019CF	3.1 None	5/14/2021	
Rm 12 Faucet	22520200-020CF	18.1 Replaced Fixture	5/14/2021	11.8
Rm 13 Faucet	22520200-021CF	9.71 None	5/14/2021	
Mens Staff Bathroom	22520200-022BF	20.1 Replaced Fixture	5/14/2021	12.6
Womens Staff Bathroom	22520200-023BF	1.61 None	5/14/2021	
Kitchen Rinse Sink	22520200-024KF	0.272 None	5/14/2021	
Kitchen Disposal Sink	22520200-025KF	0.939 None	5/14/2021	
Outside Kitchen Bathroom	22520200-026SF	10.3 None	5/14/2021	
Laundry Rm	22520200-027SF	1.02 None	5/14/2021	
Boys Locker Rm	22520200-028BF	8.91 None	5/14/2021	
Girls Locker Rm	22520200-029BF	36.7 Replaced Fixture	5/14/2021	1
Staff Bathroom Tech Buliding	22520200-030BF	31.6 Replaced Fixture	5/14/2021	6.66
Rm 9 Outside Faucet	22520200-031OS	19.7 Replaced Fixture	5/14/2021	0

Amity High School

Fixture Location	Fixture ID	Results Action Taken Date Tested		Restest
AG shop faucet	22520300-001CF	2.13 None	5/7/2021	
Wood Shop Faucet	22520300-002CF	1.67 None	5/7/2021	
Kithen Ice machine	22520300-003IM	1.83 None	5/7/2021	
Kitchen faucet south	22520300-004KF	1.81 None	5/7/2021	
Ktchen faucet West wall	22520300-005KF	1.51 None	5/7/2021	
Kithcen faucet bathroom	22520300-006BF	4.16 None	5/7/2021	

Kithcen faucet wash sink	22520300-007SF	1.53 None	5/7/2021	
upstairs mens east faucet	22520300-008BF	0.72 None	5/7/2021	
Upstairs mens west faucet	22520300-009BF	1.29 None	5/7/2021	
Upstairs womens east faucet	22520300-010BF	0.606 None	5/7/2021	
Upstais Womens West Faucet	22520300-011BF	0.964 None	5/7/2021	
215 East Faucet	22520300-012KF	1.23 None	5/7/2021	
215 SE Faucet	22520300-013KF	1.13 None	5/7/2021	
215 SW Faucet	22520300-014KF	1.19 None	5/7/2021	
215 West faucet	22520300-015KF	1.29 None	5/7/2021	
Womans Office bathroom south faucet	22520300-016BF	2.43 None	5/7/2021	
Womans Office bathroom middle 1 Faucet	22520300-017BF	0.676 None	5/7/2021	
Womans Office bathroom middle 2 Faucet	22520300-018BF	0.735 None	5/7/2021	
Womas Office bathroom North Faucet	22520300-019BF	0.86 None	5/7/2021	
Mens Office Bathroom South Faucet	22520300-020BF	3.09 None	5/7/2021	
Mens Office Bathroom middle 1 Faucet	22520300-021BF	0.844 None	5/7/2021	
Mens Office Bathroom Middle 2 faucet	22520300-022BF	0.759 None	5/7/2021	
Mens Office Bathroom North Faucet	22520300-023BF	0.85 None	5/7/2021	
Offie Staff sink front	22520300-024SF	0.784 None	5/7/2021	

Office Staff Bathroom Faucet	22520300-025BF	2.57 None	5/7/2021	
Office Staff Sink Back	22520300-026SF	1.45 None	5/7/2021	
Hall Staff Bathroom South	22520300-027BF	0.919 None	5/7/2021	
Hall Staff Bathroom North	22520300-028BF	0.79 None	5/7/2021	
Coaches Room Boys Lockeroom Faucet	22520300-029BF	4.4 None	5/7/2021	
Boys Lockerroom Faucet	22520300-030BF	0.776 None	5/7/2021	
Coaches Room Womans Locker room Faucet	22520300-031BF	22.9 Replaced Fixt	5/7/2021	9.18
Girls Lockerroom Faucet	22520300-032BF	0.801 None	5/7/2021	
Laundry Room Ice Machine	22520300-033IM	0.384 None	5/7/2021	
Boys Bathroom gym hall East Faucet	22520300-034BF	1.69 None	5/7/2021	
Boys Bathroom Gym Hall west Faucet	22520300-035BF	0.654 None	5/7/2021	
Girls Bathroom Gym Hall East Faucet	22520300-036BF	1.22 None	5/7/2021	
Girls Bathroom Gym Hall West Faucet	22520300-037BF	0.402 None	5/7/2021	
Upstairs north Drinking Fountian	22520300-038DW	1.29 None	5/7/2021	
Upstairs South Drinking Fountian	22520300-039DW	0.679 None	5/7/2021	
Office Drinking Fountian East	22520300-040DW	0.892 None	5/7/2021	
Office Drinking Fountian West	22520300-041DW	0.974 None	5/7/2021	
Gym Drinking Fountian South	22520300-042DW	0.216 None	5/7/2021	

Gym Drinking Fountian North	22520300-043DW	0 None	5/7/2021	
Gym Bottle Fill South	22520300-044BF	0.218 None	5/7/2021	
Gym Bottle Fill North	22520300-045BF	0.217 None	5/7/2021	

108 NW Faucet 1 22520300-046CF	7.57 None	5/7/2021	
108 NW Faucet 2 22520300-047CF	6.88 None	5/7/2021	
108 NE Faucet 1 22520300-048CF	11.1 None	5/7/2021	
108 NE Faucet 2 22520300-49CF	10.4 None	5/7/2021	
108 E 1 Faucet (1-4 North to South) 22520300-050CF	1.76 None	5/7/2021	
108 E 2 Faucet 22520300-051CF	2.82 None	5/7/2021	
108 E 3 Faucet 22520300-052CF	6.78 None	5/7/2021	
108 E 4 Faucet 22520300-053CF	1.39 None	5/7/2021	
108 E 5 Faucet 22520300-054CF	16.3 Replaced Fixt	5/7/2021	0
108 E 6 Faucet 22520300-055CF	5.74 None	5/7/2021	
108 E 7 Faucet 22520300-056CF	3.77 None	5/7/2021	
108 E 8 Faucet 22520300-057CF	2.08 None	5/7/2021	
CTE Buliding Bathroom 22520303-058BF	0.745 None	5/7/2021	
108 Teacher Faucet 22520300-059CF	3.32 None	5/7/2021	
107 Back Room Faucet 22520300-060SF	0 None	5/7/2021	
Office Staff Bottle Fill 22520300-061BF	0.699 None	5/7/2021	
108 Old Photo Lab Faucet 22520300-062CF	8.78 None	5/7/2021	
108 Teacher Faucet 22520300-063CF	0.699 None	5/7/2021	
107 Noth Faucet 22520300-064CF	1.6 None	5/7/2021	
107 W 1 Faucet 22520300-065CF	3.26 None	5/7/2021	
107 W 2 faucet 22520300-066CF	1.99 None	5/7/2021	
107 W3 Faucet 22520300-067CF	4.96 None	5/7/2021	
Student Center Womens Bathroom N Faucet 22520300-068BF	0.57 None	5/7/2021	
Student Center Womens Bathroom S Faucet 22520300-069BF	0.486 None	5/7/2021	

Studetn Center Mens Bathroom N Faucet 22520300-070BF	1.34 None	5/7/2021	
Student Center Mens Bathroom S Faucet 22520300-071BF	0.407 None	5/7/2021	
Library South Staff Faucet 22520300-072SF	1.5 None	5/7/2021	
Library North Staff Faucet 22520300-073SF	15.2 Replaced Fixt	5/7/2021	0
Blue Gym West Drinking Fountian 22520301-074DW	0.694 None	5/7/2021	
Blue Gym East Drinking Fountian 22520301-075DW	0.437 None	5/7/2021	
100 Classroom Faucet 22520300-076CF	0.972 None	5/7/2021	
102 Bathroom Faucet 22520300-077BF	0.72 None	5/7/2021	
102 Staff Faucet 22520300-078SF	2.99 None	5/7/2021	
Blue Gym Mens Bathroom N Faucet 22520301-079BF	1.11 None	5/7/2021	
Blue Gym Mens Bathroom Middle 1 Faucet 22520301-080BF	1.65 None	5/7/2021	
Blue Gym mens Bathroom Middle 2 Faucet 22520301-081BF	1.71 None	5/7/2021	
Blue Gym Mens Bathroom South Faucet 22520301-082BF	0.788 None	5/7/2021	
Blue Gym Womans Bathroom N Faucet 22520301-083BF	2.42 None	5/7/2021	
Blue Gym Womans Bathroom Middle 1 Faucet 22520301-084BF	1.57 None	5/7/2021	
Blue Gym Womans Bathroom Middle 2 Faucet 22520301-085BF	1.12 None	5/7/2021	
Blue Gym Womans Bathroom S Faucet 22520301-086BF	1.46 None	5/7/2021	
Outside Spigot AG Shop 22520300-087OS	57.9 Replaced Fixt	5/7/2021	0
Outside Spigot Dumpster 22520300-088OS	3.18 None	5/7/2021	
Outside Spigot SW Corner 22520300-089OS	10.3 None	5/7/2021	
Outside Spigot Outside Office 22520300-090OS	4.7 None	5/7/2021	
Outside Spigot 105 22520300-091OS	0.319 None	5/7/2021	
Outside Spigot W Library 22520300-092OS	0.351 None	5/7/2021	
Outside Spigot E Library	22520300-093OS	0.464 None	5/7/2021

Outside Spigot NE Corner	22520300-094OS	0.347 None	5/7/2021
Outside Spigot 212	22520300-095OS	0.334 None	5/7/2021
Baseball N Spigot	22520301-096OS	0.549 None	5/7/2021
Baseball S Spigot	22520301-097OS	1.68 None	5/7/2021
Softball Drinking Fountian	22520301-098OS	11.6 None	5/7/2021
Softball Spigot	22520301-099OS	0.404 None	5/7/2021
Spigot by Grandstand	22520301-100OS	1.62 None	5/7/2021
Maintenance Office Staff Sink	22520302-101SF	0.962 None	5/7/2021
Maintenane Office Bathroom Faucet E	22520302-102BF	1.56 None	5/7/2021
Maintenance Office Bathroom Faucet W	22520302-103BF	0.662 None	5/7/2021